Prüfinstitut Hoch

Lerchenweg 1 D-97650 Fladungen Tel.: int – 49 – 9778-7480-200 hoch.fladungen@t-online.de

www.reaction-to-fire.de



Test laboratory for the fire behavior of building materials, Dipl.-Ing. (FH) Andreas Hoch Testing, supervising and certifying body, authorized by the building supervision authority

TEST REPORT PZ-Hoch-160610

for the proof of Fire behaviour according to DIN 4102, part 1

Translation of the German test report – no guarantee for translation of technical terms

company

Miranda Sp. z o.o ul. Jedwabnicza 1

62-700 Turek - Polen

description of samples

white knitted fabric consisting of 100% polyester in 2 different

area weights

name of the material

"101704/WPL D/OG/320" &

"101582/WPL D/OG/320"

sampling

by the company itself

content of request

Proof of flammability to classify building materials to class B1

"schwerentflammbar" according to DIN 4102, part 1

validity of test report

31.05.2021

result

The examined product meets with a nominal area weight range of 115 g/m² up to 200 g/m² the requirements of class B1 for "schwerentflammbare" (hardly flammable) building materials according to DIN 4102, part 1 (May 1998), suspended freely or with distance of >40 mm to same or other plain materials.

This test report includes 4 pages and 6 enclosures.

Remark: If the above mentioned building material is not used as product according to MBO § 2, Abs. 9, Ziffer1, there is no need for a general building supervisory test report.

This test report is not valid if the examined building material is used as product in the meaning of state building prescriptions (MBO § 17, Abs. 3).

This test report does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building prescriptions. This has to be verified by:

"allgemeine bauaufsichtliche Zulassung" (general building inspectorate approval) or by
 "allgemeines bauaufsichtliches Prüfzeugnis" (general building inspectorate certificate) or by

"Zustimmung im Einzelfall" (exceptional approval)

This test report can underlie building supervisory procedures

- for regular building products for the prescribed proofs of conformity

for non regular building products for the needed proofs of applicability.

This test report must not be published and copied without preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents.



